

LOCATION

4401 Crimson Ct.

CITY

GASTONIA

BETWEEN

Timberwood Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	87'	11-6-07		
MAIN TO PROP LINE	5/8"	P	6'			
PROP LINE TO BLDG	5/8"	P	81'			

ENTERS

4401

BRANCHED INTO

TAP SIZE

3/4"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

15' NW. of center
of Crimson Ct.

PRESSURE TEST @

100

PSI

FOR

14

HRS

BY

Sik

MAIN-SIZE

2"

C I

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

DEPTH

3 FT

0 IN

LOCATION

40' SW. of center of Crimson Ct.

"A" P/S READING

P

TOTAL ANODES 1#

0


17#

0

LR #

323269

REMARKS



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	