

LOCATION 900 Crowdens Woods Dr. CITY Gastonia
BETWEEN Hope Marian Ct. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>109'</u>	<u>10-21-02</u>		
MAIN TO PROP. LINE	<u>5/8"</u>	<u>P</u>	<u>43'</u>	<u>"</u>		
PROP. LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>66'</u>	<u>"</u>		

ENTERS: 900 BRANCHED INTO: 0
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 55' north of


center of Hope Marian Ct.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 3' FT 0" IN LOCATION 19' West of center of Crowdens Woods Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 306376

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>service</u>