

LOCATION 1149 Crowders woods Dr. CITY GASTONIA
BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>78'</u>	<u>B-21-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>68'</u>			

ENTERS 1149 BRANCHED INTO 0
TAP SIZE 3/4 PRESSURE 100 PSI _____ INCHES W/C LOCATION 93' N of Cof Carson Rd


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2002

DEPTH 3 FT 6 IN LOCATION 19' W of Cof Crowders wood Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	