

LOCATION 1156 Crowders Woods Dr. CITY Gastonia
BETWEEN Carson Rd. STREET & Crowders View STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	101'	7-2-02		
MAIN TO PROP LINE	5/8"	P	48'	"		
PROP LINE TO BLDG	3/8"	P	53'	"		


ENTERS 1156 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 328' East of
center of Carson Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2002

DEPTH 3' FT 0" IN LOCATION 19' north of center of Crowders Woods Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00365236

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>river</u>