

LOCATION 1402 Crowders Woods DR CITY Canton, GA
 BETWEEN Carson Rd. STREET & Graywood DR STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>75'</u>	<u>6-29-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS 1402 BRANCHED INTO
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 129' S. of center of Carson Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Seth
 MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999
 DEPTH 3 FT 0 IN LOCATION 18' E of center of Crowders Woods DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 506401

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	