

LOCATION 1526 Crowder Woods Dr. CITY GASTONIA  
 BETWEEN LAurel Woods Dr. STREET & Carson Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>81</u>	<u>11-19-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>71</u>			

ENTERS 1526 BRANCHED INTO 0  
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY MM

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT IN LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

