

LOCATION 1542 Crowder woods dr CITY Gastonia  
BETWEEN Shady Oak STREET & Dead end STREET

|                   | SIZE       | TYPE      | LENGTH     | INSTALLED       | RETIRED | RENEWED |
|-------------------|------------|-----------|------------|-----------------|---------|---------|
| MAIN TO BLDG      | <u>3/4</u> | <u>P</u>  | <u>31'</u> | <u>10-12-99</u> |         |         |
| MAIN TO PROP LINE | <u>1"</u>  | <u>11</u> | <u>18'</u> |                 |         |         |
| PROP LINE TO BLDG | <u>1"</u>  | <u>11</u> | <u>13'</u> |                 |         |         |

ENTERS 1540 BRANCHED INTO 1542  
TAP SIZE 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W C LOCATION 18' E. of COJ


PRESSURE TEST 100 PSI FOR 1/4 HRS BY AP Crowder woods

MAIN SIZE 3/4 C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 1 FT 6 IN LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_



| Test Station                            |           |          |
|---|-----------|----------|
| Reading & Location                      | Lead      | Volts    |
| P/S Pipeline Lead - Red New Service     | <u>OR</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u>  |          |