

LOCATION 1705 cypress Ct CITY Bastonia  
BETWEEN Stone pine Dr. STREET & Union Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>11/14/00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>"</u>		

ENTERS 1705 cypress Ct BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 175' north of  
center of stone pine Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Hardy

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1988

DEPTH 2' FT 6" IN LOCATION 25' west of center of cypress Ct.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 1073167

REMARKS new plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>