

LOCATION 1702 CYPRESS CT CITY GASTONIA
 BETWEEN STONE PINE DR ~~STREET~~ & UNION RD ~~STREET~~

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	PLASTIC	84'	6-27-00		
MAIN TO PROP LINE	3/4"	PLASTIC	15'			
PROP LINE TO BLDG	3/4"	PLASTIC	69'			

ENTERS 1702 BRANCHED INTO 0
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 14' S. OFC OF CYPRESS CT.


PRESSURE TEST @ 100 PSI FOR 24 HRS BY RC

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 14' W. OFC OF STONE PINE DR.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	RISER PLASTIC
P/S Pipeline Lead - White Existing Main	E	