

LOCATION 211 Cypress Dr CITY GASTONIA  
 BETWEEN SPLIT OAK TRAIL STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>93'</u>	<u>10-8-02</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>"</u>	<u>16'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>1"</u>	<u>"</u>	<u>77'</u>	<u>"</u>		

ENTERS 211 Cypress Dr BRANCHED INTO N/A  
 TAP SIZE 3/4 PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION 166' South

OF Center of Split Oak Trail

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY W. Clark

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993


DEPTH 3 FT IN LOCATION 18' West of Center of

Cypress dr.

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS

RAN New 5/8 Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	