

LOCATION 2983 DAFPODIL CITY CASLERIA

BETWEEN Highway 27th Ave. STREET A STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	75	8-10-99		
MAIN TO PROP LINE	3/4	P	5			
PROP LINE TO BLDG	3/4	P	70'			

ENTERS 2983 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST @ 100 PSI FOR 114 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main		

