


LOCATION 400 DALE AVE. CITY GASTONIABETWEEN BEHIND CORNER DALE AVE STREET & OAKWOOD AVE. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>220'</u>			<u>J</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>93'</u>			<u>2-24-98</u>
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>78'</u>			

ENTERS. 400 BRANCHED INTO: _____TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 23' OFF CENTER OF DALE AVEPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION 5' WEST 1/2 OF OAKWOOD AVE
20' OFF CENTER EAST SIDE OF DALE AVE."A" P/S READING PLASTIC TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RI SER</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY