


LOCATION 405 DALE AVECITY GASTONIABETWEEN OAKWOOD AVE.STREET & CRESCENT

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>55</u>		<u>2-24-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>52</u>			

ENTERS: 405BRANCHED INTO: TAP SIZE 3/4PRESSURE 60 PSI INCHES W CLOCATION 71' WEST OF OAKWOOD AVEPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION 20' SOUTH CENTERLINE OF DALE AVE."A" P/S READING PLASTICTOTAL ANODES 1# 17# L.R. #

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R I S E R</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY