

LOCATION 408 DALE AVE.CITY GASTONIABETWEEN OAKWOOD AVE.

STREET &

CRESCENT AVE.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>48'</u>		<u>TIED-OVER</u>	<u>75' EXISTING</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>37'</u>		<u>3/4 PLASTIC</u>	<u>SERVICE</u>
PROP. LINE TO BLDG	<u>11</u>	<u>11</u>	<u>42'</u>		<u>2-25-98</u>	

ENTERS: 408BRANCHED INTO: 410TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W C

LOCATION 50'-E FROM 1/2 OF CRESCENTPRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION 18' S FROM 1/2 OF DALE AVE."A" P/S READING PLASTICTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	