

LOCATION 411 Dale Ave CITY GALENIA

BETWEEN Oakwood Ave. STREET & Dessant Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	54'	1-27-00		
MAIN TO PROP LINE	3/4"	P	5'			
PROP LINE TO BLDG	3/4"	P	49'			

ENTERS 411 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 227' E. of center of Dessant Ln.


PRESSURE TEST @ 100 PSI FOR 94 HRS BY S.H.

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 19' S. of center of Dale Ave

"A" P/S READING ? TOTAL ANODES 1# 0 17# 0 LR # 36614

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	