

LOCATION 949 Dallas - Bessmer Hwy CITY Garland

BETWEEN Vandenburg Rd STREET & Whispering Pines STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	190'	10-1-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	180'			

ENTERS: 949 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 785' NE of center of Vandenburg Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. J. Smith

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1962

DEPTH: 3 Ft. 0 In. LOCATION 14' S. of center of Dallas - Bessmer Hwy

"A" P/S READING 1.3 TOTAL ANODES 1* 0 17* 0 L.R. # 536998

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY