

LOCATION 955 Dallas Bessemer City Hwy CITY GASTONIA  
BETWEEN Fairview DR. STREET 8 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>243'</u>	<u>7-26-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>218'</u>			

ENTERS 955 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 100 PSI INCHES W C LOCATION 784' N. of center of Fairview DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN SIZE 3/4" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 2 FT 0 IN LOCATION 66' E. of center of Dallas-Bessemer City Hwy

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 599934

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	