

LOCATION ^{S.} 824 Dalton St.

CITY GASTONIA

BETWEEN 7TH

STREET & Ashton

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	2'	4-3-94	Tie over	Existing 45'
MAIN TO PROP. LINE					Cut to Plastic MAIN	
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 295 North of Ashton


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 12 East of Ashton

"A" P/S READING 1.4 TOTAL ANODES 1# 1 17# L.R. #

REMARKS: Tracer wire Not Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY