

LOCATION 831 S. DARTON CITY GASTONIA
BETWEEN Ashton Ave STREET & 7th Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>10-29-94</u>	<u>Tied over</u>	<u>44' Existing</u>
MAIN TO PROP. LINE					<u>3/4 C/W</u>	<u>Pipe</u>
PROP. LINE TO BLDG.						

ENTERS: 831 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 77' S of C of S. Darton Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 15' W of C of Ashton Ave.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 484170

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u> <u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY