

LOCATION 838 S. Dalton CITY Carterville
BETWEEN 10th STREET & Ashton STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>102994</u>	<u>Tied over</u>	<u>22' of EXT</u>
MAIN TO PROP. LINE					<u>3/4" to</u>	<u>EXT 2" Plastic</u>
PROP. LINE TO BLDG.					<u>Main</u>	

ENTERS: 838 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 100 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By ED
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:
Taper wire tied off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead — Red New Service	<u>S</u> <u>Riser</u>	<u>1.1</u>
P/S Pipeline Lead — White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY