

LOCATION 609 Dartmouth dr

CITY Gastonia

BETWEEN Fairfield dr

STREET &amp;

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	C/W	20'	6-18-94	Tied over 102	3/4 C/W Ser.
MAIN TO PROP. LINE					to Ext 2" P. main	
PROP. LINE TO BLDG.						

ENTERS: 609

BRANCHED INTO: -

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 18' W of C of  
Dartmouth dr

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In.


LOCATION

"A" P/S READING

TOTAL ANODES 1\* 1 17\*

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R	1.10
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY