

LOCATION 612 Dartmouth CITY Lynn

BETWEEN Fairfield Dr. STREET & Fairfield Dr STREET

	SIZE	TYPE	P	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.			35	55	Tap over 6-18-94		
MAIN TO PROP. LINE			35	5			
PROP. LINE TO BLDG.			0	50			

ENTERS: 412 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side House

PRESSURE TEST: @ 100 psi For 14 Hrs. By Brett


MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION: 20' W of C. Jct

"A" P/S READING 1.10 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: Dresser was bonded

~~Gas~~ Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY