

LOCATION 614 Northmouth CITY Dartmouth
BETWEEN Fairfield Dr STREET & Fairfield STREET

	SIZE	TYPE	5 LENGTH	8	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Black	74	37	10-18-94 6-18-94		
MAIN TO PROP. LINE	3/4		3	37			
PROP. LINE TO BLDG.	3/4		71	0			


ENTERS: 614 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Seiche House

PRESSURE TEST: @ 100 psi For 14 Hrs. By Barnett
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 2 Ft. 6 In. LOCATION 20' W of CP

"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Dresser was bonded

~~Bare Main Replacement Program~~
~~Bare Main Replacement Program~~



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY