

LOCATION 810 E. Davis CITY Croston

BETWEEN W. Chestnut STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|--|-----------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>CW</u> | <u>Bonded Insulated Dresser</u> | | | |
| MAIN TO PROP. LINE | | | <u>This service has a plastic riser.</u> | | | |
| PROP. LINE TO BLDG. | | | <u>Has been Retored with Plastic</u> | | | |

ENTERS: 810 BRANCHED INTO:

TAP SIZE: PRESSURE _____ PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1964

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING 1.128 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

This service has plastic Riser (Tracer wire Test point)
Ext 3/4 CW, Bonded Insulated Dresser.



| Test Station | | |
|--|--------------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>Riser</u> | <u>plastic</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY