

LOCATION 214 W. Davidson Ave CITY CAST  
BETWEEN N. York St STREET & Falls St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>57'</u>			<u>12-4-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG	<u>"</u>	<u>"</u>	<u>27'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 203' from @ of N. York St

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY mf  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT 0 IN. LOCATION Southside of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY