

LOCATION 215 W. Davidson Ave CITY CAST.
BETWEEN N. York St. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>46'</u>		<u>12-4-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>39'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 201' from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 44 HRS BY MM
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 94
DEPTH: 3 FT. 0 IN LOCATION South Side of W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY