

LOCATION 216 W. Davidson Ave CITY Cast.
BETWEEN N. York St. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45'</u>		<u>12-4-96</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>39'</u>			

ENTERS: Sam r BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 115' from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY my
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96
DEPTH: 3 FT 0 IN LOCATION NORTH SIDE OF W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY