

LOCATION 306 W. Davidson Ave CITY CRST.

BETWEEN Aug 321 STREET & N. York St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>41'</u>		<u>11-15-96</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>37'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 169' from (P) of W. Davidson Ave


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY ML

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION NORTHSIDE OF W. Davidson Ave

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY