

LOCATION 403 West Davidson Ave CITY Atlanta
BETWEEN North York STREET & May 321 North STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>14'</u>		<u>11-26-</u>	<u>96</u>
MAIN TO PROP. LINE			<u>7'</u>			
PROP. LINE TO BLDG.			<u>7'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 368' from C of North York Street


PRESSURE TEST: @ 100 PSI FOR 4 HRS BY N. McStumey

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3' FT 0 IN LOCATION North side of W. Davidson Ave.

"A" P/S READING P TOTAL ANODES 1# - 17# - I.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY