

LOCATION 411 W Davidson Ave CITY GAstonia  
BETWEEN N York STREET & N 321 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	62'	1/19/96		
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4"		47'			

ENTERS: 411 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL / PLASTIC \_\_\_\_\_ YEAR INSTALLED 1953

DEPTH: 2 FT. 6 IN. LOCATION

"A" P/S READING 25 TOTAL ANODES 1# 2 17# 1 L.R. # 003833

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY