


LOCATION 435 W. DavidsonCITY GASTONIABETWEEN BoycSTREET & 321 N

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>1' used to</u>	<u>11-25-91</u>		
MAIN TO PROP. LINE			<u>Tie over C/W</u>			
PROP. LINE TO BLDG.			<u>Sev.</u>			

ENTERS: 437BRANCHED INTO: 435TAP SIZE: 3/4PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991DEPTH: 1 Ft. 6 In.LOCATION 28' E. of C of Boyce"A" P/S READING _____ TOTAL ANODES 1# 1 17# _____ L.R. # _____REMARKS: Tracer wire tied off

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>1.150</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY