


LOCATION 519 W. DavidsonCITY GastoniaBETWEEN BoyleSTREET & Morris

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>44' plastic to</u>	<u>11-22-91</u>		
MAIN TO PROP. LINE			<u>Tie-over C/W</u>			
PROP. LINE TO BLDG.			<u>serv.</u>			

ENTERS: 519BRANCHED INTO: 517, 519ATAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GPMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991DEPTH: 2 Ft. 6 In. LOCATION 19' W. of C of W. Davidson"A" P/S READING 0 TOTAL ANODES 1# 1 17# _____ L.R. # _____REMARKS: Tracer wire tied off at service split
Bonded dresser

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.050</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY