

LOCATION 611 & 613 W. Davidson CITY GAST.

BETWEEN Morris STREET & Pryor STREET

	SIZE	TYPE	611 LENGTH	613	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	43'	20'		6-26	-96
MAIN TO PROP. LINE	"	"	4'	0'			
PROP. LINE TO BLDG.	"	"	39'	20			

ENTERS: 611 BRANCHED INTO: 613

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION W. of 611
E. of 613


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. side of W. Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY