

LOCATION 615 W. DAVIDSON AVE CITY Host.

BETWEEN More's STREET & Pryor STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>J</u>	<u>38</u>		<u>6-26</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>35</u>			

ENTERS: 615 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E. of 615

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. side of W. Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		