

LOCATION 812 W Davidson Ave CITY CASSTONIA
BETWEEN Highland STREET & Weldon STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>77' EXIST</u>	<u>Tie Over</u>		
MAIN TO PROP. LINE			<u>45' New</u>	<u>8-24-96</u>		
PROP. LINE TO BLDG.			<u>(122' TOTAL)</u>			

ENTERS: 812 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 26' N OF Davidson

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M. Parker
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 96
DEPTH: 3 FT. 0 IN. LOCATION 326' W OF N Highland.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>A-Riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		