

LOCATION 902 & 904 W. DAVIDSON CITY GAST
BETWEEN WELDON STREET & RANSOM STREET

	SIZE	TYPE	904 LENGTH 902	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	86' 20		7-26-96	
MAIN TO PROP. LINE	"	"	36' 0			
PROP. LINE TO BLDG.	"	"	50' 20			

ENTERS: 904 BRANCHED INTO: 902
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION W of 902
E of 904


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S side of W Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	D
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY