

LOCATION 918 W Davidson CITY GASTONIA

BETWEEN Weldon STREET & Ransom STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>TIED OVER</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>41' EXIST 3/4"</u>	<u>12-14-96</u>		
PROP. LINE TO BLDG.			<u>34' NEW</u>			

ENTERS: 918 75 TOTAL BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 128' E OF Ransom


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M. Pugh

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL # PLASTIC K YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION 20' N OF W Davidson

"A" P/S READING P-riser TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		