

LOCATION 1108 + 1106 W Davidson Ave CITY GASTONIA  
BETWEEN RANSON STREET & Glenn STREET


	SIZE	TYPE	1108 LENGTH 1106	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>(69' 3/4)</u> <u>EXIST</u> <u>15'</u> <u>EXIST</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>31'</u> <u>NEW</u> <u>3/4"</u> <u>TIED OVER</u>	<u>12-14-96</u>		
PROP. LINE TO BLDG.			<u>100' TOTAL</u>			

ENTERS: 1108 BRANCHED INTO: 1106  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 190' W OF RANSON

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY M. Park  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 96  
DEPTH: 3 FT. 0 IN. LOCATION 13' S OF Davidson

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-Riser</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		