

LOCATION 1112 E 1114 W. Davidson CITY East
BETWEEN Ransom STREET & Glenn STREET

	SIZE	TYPE	1114 LENGTH	1112	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	102'	13'		7 - 30	96
MAIN TO PROP. LINE	"	"	35'	0			
PROP. LINE TO BLDG.	"	"	67'	13			

ENTERS: 1114 BRANCHED INTO: 1112
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION E of 1114
W of 1112


PRESSURE TEST: @ 100 PSI FOR 114 HRS. BY GL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. of W. Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY