

LOCATION 1121 W. DAVIDSON AVE CITY GAST
BETWEEN RANSOM STREET & GLEN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	<u>PA</u>	99'		8-2	-96
MAIN TO PROP. LINE	-1	"	5'			
PROP. LINE TO BLDG.	"	"	94'			

ENTERS: 1121 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. of 1121

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GLL
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96
DEPTH: 3 FT. IN. LOCATION S. of W. Davidson

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>✓</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY