

LOCATION 1503 + 1507 W. DavidsonCITY ConroeBETWEEN Evening Shade

STREET &amp;

STREET

	SIZE	TYPE	1503 LENGTH	1507	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Ø	12'	52			
MAIN TO PROP LINE							
PROP. LINE TO BLDG.							

ENTERS: 1503BRANCHED INTO: 1507TAP SIZE: 3/4PRESSURE 20 PSI

INCHES W C

LOCATION

PRESSURE TEST: @ 105 PSIFOR 44 HRS.BY EDMAIN-SIZE 3/4

C.I. \_\_\_\_\_

BARE STEEL \_\_\_\_\_

COATED STEEL ☒

PLASTIC \_\_\_\_\_

YEAR INSTALLED \_\_\_\_\_

DEPTH: 3 FT 0 IN


LOCATION

"A" P/S READING 1.0TOTAL ANODES 1# Ø17# Ø

L.R. # \_\_\_\_\_

REMARKS:

Tracer wire bonded to Ext 3/4 GWS pipe  
Tracer wire test point at Riser.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R.S.W</u>	<u>1.056V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY