

LOCATION 1706 W. DavidsonCITY GastoniaBETWEEN Evening ShadeSTREET & Holly Leaf

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>0'</u>	<u>Relocated</u>	<u>9-9-87</u>	
MAIN TO PROP. LINE				<u>Used Ext.</u>	<u>C/W Riser.</u>	
PROP. LINE TO BLDG.						


ENTERS: 1706BRANCHED INTO: 0TAP SIZE: 3/4 Ser.PRESSURE 60 PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EPMAIN-SIZE 3/4 C.I.      BARE STEEL      COATED STEEL ✓ PLASTIC      YEAR INSTALLED     DEPTH: 2 FT 0 IN. LOCATION"A" P/S READING 1.1TOTAL ANODES 1# 0 17# 0L.R. #     

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY