

LOCATION 913 Davis St. CITY GASTONIA

BETWEEN CHURCH St. STREET & Belvedere Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>55'</u>		<u>6-</u>	<u>5-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>27'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>28'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES WC LOCATION 414 from (S) of

CHURCH St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.H.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION northside of Davis

"A" P/S READING P. TOTAL ANODES 1# 1 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY