

LOCATION 300 Davis Park Rd. CITY Castroville

BETWEEN Weston Ave. STREET & Crawford St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>1-20-99</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>39'</u>			

ENTERS: 300 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 98' E. of center of

Weston Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Stubbstaetter

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 12' S. of center of Davis Park Rd.

"A" P/S READING .6 TOTAL ANODES 1# 0 17# 1 L.R. # 58027

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY