

LOCATION 418 Davis Park Road

CITY Gastonia

BETWEEN Weston St

STREET & Lamar Ave

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:	PRESSURE _____ P.S.I. _____ INCHES W.C.	LOCATION
-----------	---	----------


PRESSURE TEST: @ _____ psi For _____ Hrs. By _____

MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION _____

"A" P/S READING 1.020 TOTAL ANODES 1* / 17* _____ L.R. # _____

REMARKS: Installed 1-16 anode to IS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY