


LOCATION 514 Davis Park Rd. CITY WASTONIA
 BETWEEN Fallsdale Dr. STREET & 321 South STREET
 MAIN TO BLDG 5/8" Plastic 110' 6-6-02
 MAIN TO PROP LINE 5/8" Plastic 30'
 PROP LINE TO BLDG 5/8" Plastic 80'
 ENTERS 514 BRANCHED INTO 0
 TAP SIZE 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION 46' E of C of Weston St.
 PRESSURE TEST @ 100 PSI FOR 44 HRS BY RL
 MAIN SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960
 DEPTH 3 FT 6 IN LOCATION 13' S of C of Davis Park Rd.
 "A" P/S READING 1.1 TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

COPY