

LOCATION 801 Davis Park Rd. CITY Gastonia
BETWEEN Monk Ave. STREET & Stagecoach Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/8"</u>	<u>P</u>	<u>118'</u>	<u>10-3-01</u>		
MAIN TO PROP LINE	<u>3/8"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/8"</u>	<u>P</u>	<u>103'</u>			


ENTERS 801 BRANCHED INTO
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 40' W. of center of Monk Ave.

PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.
MAIN-SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960

DEPTH 2 FT. 0 IN LOCATION 10' S. of center of Davis Park Rd.

"A" P/S READING 1. TOTAL ANODES 1# 0 17# 0 LR # C81548

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	