

LOCATION 1618 DAVIS PARK RD CITY GASTONIA
BETWEEN GARLAND STREET & AMERICAN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>Tied on</u>		<u>2-9-00</u>
MAIN TO PROP LINE						
PROP. LINE TO BLDG.						

ENTERS: 1627 American BRANCHED INTO: 1618 DAVIS PK. RD.
TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST @ 100 PSI FOR 14 HRS BY ED.
MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 1 FT 6 IN LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # _____
REMARKS:

This Service is a Isolated Service
part 3/4 Gue, part plastic



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>As Set</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	