

LOCATION 2012 Davis Park Rd. CITY BASTONIA
BETWEEN Danbury STREET & Davis Park Rd. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>82'</u>	<u>7-11-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>70'</u>			

ENTERS: 2012 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 189' w of Cof Danbury

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1980
DEPTH: 3 FT. 6 IN. LOCATION 22' S of Cof Hudson Blvd.

"A" P/S READING 1.2 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	E	<u>Plastic</u>

ENG. DEPT. USE ONLY