

LOCATION 2436 Davis Park Rd. CITY Gastonia  
BETWEEN Glenraven Ave. STREET & Cedar Oak Cir. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>133'</u>	<u>1-22-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>103'</u>	<u>"</u>		

ENTERS 2436 Davis Park Rd BRANCHED INTO 5  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 60' north


of center of Cedar Oak Cir.  
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.F.

MAIN-SIZE 6' C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1961

DEPTH 3' FT 2" IN LOCATION 13' East of center of Davis Park Rd.

"A" P/S READING 0.8 TOTAL ANODES 1# \_\_\_\_\_ 17# 40 LR # 11737

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>rise</u>